

**GRADATION ANALYSIS TEST REPORT**

for Product: 4/10/

Supplier/ source: Dagenham

Material type: Drystone aggregate Test method: Wash grading to BS EN 932-1: 1997

**SAMPLE INFORMATION**

Sampled/ tested

Thu 05 May 2022/ 16-05-22  
at 0000 hrs

Sample number GDAT\_13037\_01BD

Location	-	Chainage/layer	-
Ticket/truck number	-	Weather conditions	-
Sampling notes	-	Aggregate type	-
Remarks 1	-	Remarks 2	-

**SAMPLE ANALYSIS**


Sieve size	Percent passing	Specification limits	Complies ?
20mm	100	100 - 100	yes
16mm	100	-	-
14mm	100	98 - 100	yes
10mm	93	85 - 100	yes
8mm	70	-	-
6.3mm	45	-	-
4mm	9	0 - 20	yes
2.8mm	3	-	-
2mm	2	0 - 5	yes
63µm	1	-	-
Moisture content %	3.2	not specified	-
Flakiness index	no result	<=35	-

Parameters are evaluated to the accuracy of spec. limits

**REMARKS**

Compliance status ok  
Category A of A-C includes secondary parameters

-----  
-----  
-----  
-----  
-----  
-----  
-----



Signed \_\_\_\_\_

Print date 24 May 2022