

**GRADATION ANALYSIS TEST REPORT**  
**for Product: 02693/ 4/10 SINGLE SIZE GRAVEL**  
**Supplier/ source: South East - Northfleet**  
 Material type: Drystone aggregate Test method: Wash grading to BS EN 932-1: 1997

**SAMPLE INFORMATION**

Sampled/ tested  
 Thu 28 April 2022/ 10-05-22  
 at 0000 hrs

**Sample number** GDAT\_12776\_01BD

Location - Chainage/layer -  
 Ticket/truck number - Weather conditions -  
 Sampling notes - Aggregate type -  
 Remarks 1 - Remarks 2 -


**SAMPLE ANALYSIS**

Sieve size	Percent passing	Specification limits	Complies ?
20mm	100	100 - 100	yes
16mm	100	-	-
14mm	100	98 - 100	yes
10mm	98	85 - 100	yes
8mm	77	-	-
6.3mm	46	-	-
4mm	4	0 - 20	yes
2.8mm	1	-	-
2mm	0	0 - 5	yes
63µm	0.1	0.0 - 4.0	yes
Moisture content %	3.2	not specified	-
Uniformity coefficient	2	=>1	yes
Flakiness index	no result	<=35	-
Chloride content %	no result	<=0.030	-

Parameters are evaluated to the accuracy of spec. limits

**REMARKS**

Compliance status ok  
 Category A of A-C includes secondary parameters



Signed \_\_\_\_\_

Print date 24 May 2022