

GRADATION ANALYSIS TEST REPORT
for Product: 03333/ 10/20 SINGLE SIZE GRAVEL
Supplier/ source: South East - Northfleet
 Material type: Drystone aggregate Test method: Wash grading to BS EN 932-1: 1997

SAMPLE INFORMATION

Sampled/ tested
 Thu 28 April 2022/ 10-05-22
 at 0000 hrs

Sample number GDAT_12779_01BD

Location - Chainage/layer -
 Ticket/truck number - Weather conditions -
 Sampling notes - Aggregate type -
 Remarks 1 - Remarks 2 -


SAMPLE ANALYSIS

Sieve size	Percent passing	Specification limits	Complies ?
40mm	100	100 - 100	yes
31.5mm	100	98 - 100	yes
20mm	94	85 - 100	yes
16mm	64	-	-
14mm	48	-	-
10mm	8	0 - 20	yes
8mm	2	-	-
6.3mm	1	-	-
4mm	0	0 - 5	yes
63µm	0.1	0.0 - 4.0	yes
Moisture content %	0.9	not specified	-
Flakiness index	no result	<=35	-
Chloride content %	no result	<=0.030	-

Parameters are evaluated to the accuracy of spec. limits

REMARKS

Compliance status ok
 Category A of A-C includes secondary parameters



Signed _____

Print date 24 May 2022